

Product	Connecting Device for AL-conductor
Applicant	Elis Elektro AS Jerikoveien 16 1067 Oslo Norway
Manufacturer	Zhejiang Yuelong Machinery Electrical Co., Ltd. #199 Yaao Road, Daqiao Town, Nanhu District ,Jiaying China
Factory	Zhejiang Yuelong Machinery Electrical Co., Ltd. #199 Yaao Road, Daqiao Town, Nanhu District ,Jiaying China <input type="checkbox"/> See next page(s)
Ratings	Al 25-50/Cu16 750V / 50Hz
Trade mark	L&G
Model / Type Ref.	L&G XJ(c)-LJ(s)
Principal characteristics	1-pole separate entity terminal, non-reusable. With insulating piercing clamping unit for connecting 25 - 50mm ² stranded Al-conductor only. With permanent mounted 16mm ² Cu flexible wire, current rating as for 16mm ² Cu-conductor, all colours, with end sleeve. <input type="checkbox"/> See next page(s)
A sample of the product was tested and found to be in conformity with	INST EN 60998-2-3:2004 EN 60998-1:2004
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	Also tested for relvant parts of IEC 61545: 1996. <input type="checkbox"/> See next page(s)
Additional model(s)	<input type="checkbox"/> See next page(s)

Date of issue 14-02-2014



Skule Moe

Certification Department

Nemko ASGautstadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532